

GARAGE DOOR

1/2" EXP. JOINT MATERIAL

CONC. STEMWALL PER PLAN
W/ (3)-#4 CONT. HORIZ REBARS
W/ #4 VERT. STAB OUT REBAR
@ 24" O/C, BENT INTO DRIVEWAY

4" CONC. DRIVEWAY SLAB
REINF. AS REQUIRED
MIN. 2% GRADE
CONTROL JOINTS @ 10' MAX.

4" CONCRETE SLAB
REINF. AS REQUIRED

WATERPROOFING
TO GRADE

95% COMPACTED
BACK FILL

4" GRAVEL BASE
AS REQUIRED

6 MIL POLYETHYLENE
VAPOR BARRIER

95% COMPACTED
BACK FILL

1'-6" (MIN.)

4" GRAVEL BASE
AS REQUIRED

10"

#4 VERT. DOWELS
@ 24" O/C

4" DIA RIGID PERF. PVC
FOOTING DRAIN PIPE
MIN. 2% SLOPE TO DAYLIGHT

CONC. FTG PER PLAN
W/ (2)-#4 CONT. HORIZ
REBARS

8"

1'-8"

3/4" WASHED DRAIN GRAVEL
W/ FILTER FABRIC

