

**TABLE R301.2(1)
CLIMATIC AND GEOGRAPHIC DESIGN CRITERIA FOR
GILA COUNTY**

ROOF/GROUND SNOW LOADS * (psf)	below 2000 ft = Roof 0 / Ground 0 2000 to 4500 ft = Roof 20/ Ground 25 4500 to 6000 ft = Roof 40/ Ground 50 Above 6000 ft = per historical data available	
WIND SPEED	90 m.p.h. – 3 second gust wind velocity 75 m.p.h. – fastest mile wind speed	
SEISMIC DESIGN CATEGORY	C	
WINTER DESIGN TEMPERATURE	4500 ft and above = 15° below 4500 ft = 24°	
ICE SHIELD UNDERLAYMENT REQUIRED	NO	
FLOOD HAZARDS	As determined by the Floodplain Department/Engineer	
AIR FREEZING INDEX	Less than 1500 cumulative degree days below freezing County-wide	
MEAN ANNUAL TEMPERATURE	61.8° average County-wide	
SUBJECT TO DAMAGE FROM		
WEATHERING	Moderate at 4600 feet and above Negligible below 4600 feet	
FROST (footing depths)	Below 4900 feet	Bottom of footing must be a min. of 12” below finish grade <u>and</u> a min. of 12” into undisturbed soil.
	4900 feet and above	Bottom of footing must be a min. of 18” below finish grade <u>and</u> a min. of 12” into undisturbed soil.
TERMITES	Moderate to Heavy	
DECAY	None to Slight	

* Roofs must be designed to support loads as specified in R301.6 **or** the snow load shown here, whichever is greater. (Ground Snow Load x .8 ≈ Roof Snow Load)

Gila County Community Development
745 N Rose Mofford Way
Globe, Arizona 85501
928-425-3231 Ext. 4224
Fax 928-425-0829

Gila County Community Development
608 E Highway 260
Payson, Arizona 85541
928-474-9276
Fax 928-474-0802

800-304-4452
Extension 4224 for Globe Office
Extension 7110 for Payson Office