



# Snow Load Report

## 1. Roof and Building Data

Ground Snow Load (Pg): 93.0 psf  
 Roof Pitch: 6 /12  
 Risk Category: II  
 Eave-to-Ridge (W): 17 ft.  
 Terrain Category: B  
 Exposure: Partially Exposed  
 Thermal Factor (Ct): 1.00  
 Roof Surface: Metal  
 Roof System: Rafter  
 Spacing: 16 in. o/c  
 Overhang: 24 in.

## 2. Design Loads

Top Chord Dead Load: 10 psf  
 Bottom Chord Dead Load: psf  
 SF (Slope Factor) =  $1/\text{Cosine}(\Phi) = 1.12$  (Dead loads specified on a projected horizontal basis take into account the effect of the pitch via a slope factor.)  
 Adj. TCDL (TCDL x SF): 11.2 psf

## 3. Design Assumptions

Code Standard: ASCE 7-10  
 Number of Plies: 1 PLY  
 Bottom Chord Pitch: 0 /12

## 4. Snow Load Calculations

Calculate flat roof snow load  $p_f$  using the following equation:

$$p_f = 0.7C_eC_tI_s p_g$$

where:

$p_f$  = Flat Roof Snow Load in psf  
 $C_e = 1.00$  = Exposure Factor, as determined by ASCE 7-10 Table 7-2 (Terrain Cat. B, Exp. Partially Exposed)  
 $C_t = 1.00$  = Thermal Factor, as determined by ASCE 7-10 Table 7-3  
 $I_s = 1.00$  = Importance Factor, as determined by ASCE 7-10 Table 1.5-2 (Risk Cat. II)  
 $p_g = 93.0$  psf = Ground Snow Load in psf

$$p_f = 0.7C_eC_tI_s p_g = 0.7(1.00)(1.00)(1.00)(93.0) = 65.1 \text{ psf}$$

Subject Snow Loads	Customer Dominic Fontana	Location 164 Kiwassa Rd	Job No. Pino
Engr. Engineer	Company Name 123 Street City, State 12345 ph. (888) 777-5555 www.website.com		Rev. -
Date 12/15/2024			Page 1
<small>Copyright © 2024</small>			

This report may not be copied, reproduced or distributed without the written consent of Company Name

A minimum roof snow load,  $p_m$  shall apply to monoslope, hip and gable roofs with slopes less than 15 degrees using the following equations:

Where  $p_g$  is 20 psf or less:  $p_m = I_s p_g$

Where  $p_g$  exceeds 20 psf:  $p_m = I_s (20)$

**Roof slope is greater than 15 degrees, the minimum roof snow load,  $p_m$ , does not apply.**

For locations where  $p_g$  is 20 psf or less, but not zero, all roofs with slopes (in degrees) less than  $W/50$  with  $W$  in feet shall included a 5 psf rain-on-snow surcharge load. This additional load applies only to the sloped roof (balanced) load case and need not be used in combination with drift, sliding, unbalanced, minimum, or partial loads.

**Roof slope in degrees ( $26.57^\circ$ ) is greater than  $W/50 = 0.3$ , the 5.0 psf rain-on-snow surcharge load does not apply.**

Calculate sloped roof snow load  $p_s$  using the following equation:

$$p_s = C_s p_f$$

where:

$p_s$  = Sloped Roof Snow Load in psf

$C_s = 1 - [(26.57 - 5) / 65] = 0.67$  = Roof Slope Factor, as determined by ASCE 7-10 Sec. 7.4.1-7.4.4 and Figure 7-2

$p_f$  = Flat Roof Snow Load in psf

**Roof surface (Metal) is considered a "slippery" roof. For a  $C_t = 1.00$  the roof slope factor  $C_s$  is given by the dashed line of ASCE 7-10 Figure 7-2a.**

$$p_s = C_s p_f = (0.67)(65.1) = 43.5 \text{ psf}$$

Calculate unbalanced snow load for hip and gable roofs as shown in ASCE 7-10 Figure 7-5.

Unbalanced snow loads are required for roof pitches between 1/2 on 12 to 7 on 12.

Using the following equations:

$$\gamma = 0.13 p_g + 14 \text{ (snow density)}$$

$$h_d = .43 \sqrt[3]{l_u^4 p_g} + 10 - 1.5 \text{ (drift height) [if } l_u < 20 \text{ ft., use } l_u = 20 \text{ ft.]}$$

$$l_d = \frac{8}{3} h_d \sqrt{S} \text{ (width of drift surcharge)}$$

$$p_d = h_d \gamma / \sqrt{S} \text{ (drift surcharge snow load)}$$

where:

$\gamma$  = Snow density in pcf, not to exceed 30 pcf.

$h_d$  = Drift height in feet, as determined by eqn. or ASCE 7-10 Fig. 7-9.


$l_u = W$  = Ridge to eave distance in feet, windward side of roof.

$S = 12/\text{Roof Pitch}$

$l_d$  = Width of drift surcharge in feet.

$p_d$  = Drift Surcharge Snow Load in psf



Subject <b>Snow Loads</b>	Customer <b>Dominic Fontana</b>	Location <b>164 Kiwassa Rd</b>	Job No. <b>Pino</b>
Engr. <b>Engineer</b>	Company Name <b>123 Street City, State 12345</b> ph. (888) 777-5555 www.website.com		Rev. <b>-</b>
Date <b>12/15/2024</b>			Page <b>2</b>
<small>This report may not be copied, reproduced or distributed without the written consent of Company Name</small>			<small>Copyright © 2024</small>

For a roof rafter system with  $W \leq 20$  ft., the simplified unbalanced snow load is given by the third diagram of ASCE Figure 7-5.


$$p_{\text{windward}} = 0.0 \text{ psf}$$

$$p_{\text{leeward}} = I_s p_g = (1.00)(93.0) = 93.0 \text{ psf}$$

On warm roofs apply a distributed  $2p_f$  snow load on all overhanging portions as per ASCE 7-10 section 7.4.5.

No other loads except dead loads shall be present on the roof when this uniformly distributed load is applied.

$$2p_f = (2)(65.1) = 130.2 \text{ psf}$$




$$R_1 = D + S = 253.4 \text{ lbs} + 985.9 \text{ lbs}$$


$$R_2 = D + S = 253.4 \text{ lbs} + 985.9 \text{ lbs}$$

Subject	Snow Loads	Customer	Dominic Fontana	Location	164 Kiwassa Rd	Job No.	Pino	
Engr.	Engineer	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555 www.website.com				This report may not be copied, reproduced or distributed without the written consent of Company Name	Rev.	-
Date	12/15/2024						Page	3





$R_1 = D + S = 253.4 \text{ lbs} + 456.7 \text{ lbs}$   
 $R_2 = D + S = 253.4 \text{ lbs} + 1651.3 \text{ lbs}$



$R_1 = D + S = 253.4 \text{ lbs} + 347.2 \text{ lbs}$   
 $R_2 = D + S = 253.4 \text{ lbs} + 347.2 \text{ lbs}$

Subject <b>Snow Loads</b>	Customer <b>Dominic Fontana</b>	Location <b>164 Kiwassa Rd</b>	Job No. <b>Pino</b>
Engr. <b>Engineer</b>	<b>Company Name</b> 123 Street City, State 12345 ph. (888) 777-5555    www.website.com		Rev. -
Date <b>12/15/2024</b>			
			Copyright © 2024

This report may not be copied, reproduced or distributed without the written consent of Company Name