



# Snow Load Report

## 1. Roof and Building Data

Ground Snow Load (Pg): 26.0 psf  
 Roof Pitch: 3 /12  
 Risk Category: II  
 Eave-to-Ridge (W): 10 ft.  
 Terrain Category: C  
 Exposure: Fully Exposed  
 Thermal Factor (C<sub>t</sub>): 1.10  
 Roof Surface: Metal  
 Roof System: Common Truss  
 Spacing: 36 in. o/c  
 Overhang: 0 in.

## 2. Design Loads

Top Chord Dead Load: 2 psf  
 Bottom Chord Dead Load: .5 psf  
 SF (Slope Factor) = 1/Cosine(Φ) = 1.03 (Dead loads specified on a projected horizontal basis take into account the effect of the pitch via a slope factor.)  
 Adj. TC DL (TC DL x SF): 2.1 psf

## 3. Design Assumptions

Code Standard: ASCE 7-10  
 Number of Plies: 1 PLY  
 Bottom Chord Pitch: 0 /12

## 4. Snow Load Calculations

Calculate flat roof snow load p<sub>f</sub> using the following equation:

$$p_f = 0.7C_eC_tI_s p_g$$

where:

p<sub>f</sub> = Flat Roof Snow Load in psf  
 C<sub>e</sub> = 0.90 = Exposure Factor, as determined by ASCE 7-10 Table 7-2 (Terrain Cat. C, Exp. Fully Exposed)  
 C<sub>t</sub> = 1.10 = Thermal Factor, as determined by ASCE 7-10 Table 7-3  
 I<sub>s</sub> = 1.00 = Importance Factor, as determined by ASCE 7-10 Table 1.5-2 (Risk Cat. II)  
 p<sub>g</sub> = 26.0 psf = Ground Snow Load in psf

$$p_f = 0.7C_eC_tI_s p_g = 0.7(0.90)(1.10)(1.00)(26.0) = 18.0 \text{ psf}$$

Subject Snow Loads	Customer Andrew Rogers	Location 19289 Pase Pobles Ave	Job No. 913
Engr. Avery	Spectra Group 2320 Greystone Drive ph. 8015925751 None		Rev. -
Date 2/23/2026			Page 1

This report may not be copied, reproduced or distributed without the written consent of Company Name

A minimum roof snow load,  $p_m$  shall apply to monoslope, hip and gable roofs with slopes less than 15 degrees using the following equations:

Where  $p_g$  is 20 psf or less:  $p_m = I_s p_g$

Where  $p_g$  exceeds 20 psf:  $p_m = I_s(20)$

Minimum roof snow load of  $p_m = I_s(20) = 1.00 \times 20 = 20.0$  psf controls.

$p_f = p_m = 20.0$  psf

For locations where  $p_g$  is 20 psf or less, but not zero, all roofs with slopes (in degrees) less than  $W/50$  with  $W$  in feet shall included a 5 psf rain-on-snow surcharge load. This additional load applies only to the sloped roof (balanced) load case and need not be used in combination with drift, sliding, unbalanced, minimum, or partial loads.

Roof slope in degrees ( $14.04^\circ$ ) is greater than  $W/50 = 0.2$ , the 5.0 psf rain-on-snow surcharge load does not apply.

Calculate sloped roof snow load  $p_s$  using the following equation:

$$p_s = C_s p_f$$

where:

$p_s$  = Sloped Roof Snow Load in psf

$C_s = 1 - [(14.04 - 10)/60] = 0.93$  = Roof Slope Factor, as determined by ASCE 7-10 Sec. 7.4.1-7.4.4 and Figure 7-2

$p_f$  = Flat Roof Snow Load in psf

Roof surface (Metal) is considered a "slippery" roof. For a  $C_t = 1.10$  the roof slope factor  $C_s$  is given by the dashed line of ASCE 7-10 Figure 7-2b.

$$p_s = C_s p_f = (0.93)(20.0) = 18.7 \text{ psf}$$

Calculate unbalanced snow load for hip and gable roofs as shown in ASCE 7-10 Figure 7-5.

Unbalanced snow loads are required for roof pitches between 1/2 on 12 to 7 on 12.

Using the following equations:

$$\gamma = 0.13 p_g + 14 \text{ (snow density)}$$

$$h_d = .43 \sqrt[3]{l_u} \sqrt{p_g + 10} - 1.5 \text{ (drift height) [if } l_u < 20 \text{ ft., use } l_u = 20 \text{ ft.]}$$

$$l_d = \frac{8}{3} h_d \sqrt{S} \text{ (width of drift surcharge)}$$

$$p_d = h_d \gamma / \sqrt{S} \text{ (drift surcharge snow load)}$$

where:

$\gamma$  = Snow density in pcf, not to exceed 30 pcf.

$h_d$  = Drift height in feet, as determined by eqn. or ASCE 7-10 Fig. 7-9.

$l_u = W$  = Ridge to eave distance in feet, windward side of roof.

$S$  = 12/Roof Pitch

$l_d$  = Width of drift surcharge in feet.

$p_d$  = Drift Surcharge Snow Load in psf




FIGURE 7-5 Balanced and Unbalanced Snow Loads for Hip and Gable Roofs.

Subject Snow Loads	Customer Andrew Rogers	Location 19289 Pase Pobles Ave	Job No. 913
Engr. Avery	Spectra Group 2320 Greystone Drive ph. 8015925751 None		Rev. -
Date 2/23/2026			Page 2

This report may not be copied, reproduced or distributed without the written consent of Company Name

$$p_{\text{windward}} = 0.3p_s = (0.3)(16.8) = 5.0 \text{ psf}$$

$$p_{\text{leeward}} = p_s = 16.8 \text{ psf}$$

$$\gamma = 0.13(26.0) + 14 = 17.38 \text{ pcf}$$

$$h_d = .43\sqrt[3]{20}\sqrt[4]{26.0 + 10} - 1.5 = 1.36 \text{ ft. } [l_u = 20 \text{ ft.}]$$


$$l_d = \frac{8}{3} \times 1.36 \times \sqrt{12/3} = 7.25 \text{ ft.}$$

$$p_d = \frac{1.36 \times 17.38}{\sqrt{12/3}} = 11.8 \text{ psf}$$

On warm roofs apply a distributed 2pf snow load on all overhanging portions as per ASCE 7-10 section 7.4.5.

No other loads except dead loads shall be present on the roof when this uniformly distributed load is applied.

No overhang, Ice dam and icicle loads along roof eaves does not apply.




$$R_1 = D + S = 76.8 \text{ lbs} + 559.6 \text{ lbs}$$

$$R_2 = D + S = 76.8 \text{ lbs} + 559.6 \text{ lbs}$$

Subject Snow Loads	Customer Andrew Rogers	Location 19289 Pase Pobles Ave	Job No. 913
Engr. Avery	Spectra Group 2320 Greystone Drive ph. 8015925751 None		Rev. -
Date 2/23/2026			Page 3

This report may not be copied, reproduced or distributed without the written consent of Company Name



$R_1 = D + S = 76.8 \text{ lbs} + 321.3 \text{ lbs}$   
 $R_2 = D + S = 76.8 \text{ lbs} + 590.9 \text{ lbs}$

Subject	Snow Loads	Customer	Andrew Rogers	Location	19289 Pase Pobles Ave	Job No.	913
Engr.	Avery	<b>Spectra Group</b> 2320 Greystone Drive ph. 8015925751 None		<small>This report may not be copied, reproduced or distributed without the written consent of Company Name</small>	Rev.	-	
Date	2/23/2026				Page	4	